

TEKNOS A/S
 Industrivej 19
 6580 Vamdrup
 DENMARK

Eurofins Product Testing A/S
 Smedeskovvej 38
 8464 Galten
 Denmark

CustomerSupport@eurofins.com
 www.eurofins.com/VOC-testing

VOC EMISSION TEST REPORT


Indoor Air Comfort GOLD®

10 November 2021

1 Sample Information

| | |
|------------------------|-------------------------------|
| Sample name | TEKNOSAFE FLAME GUARD 2467-10 |
| Batch no. | - |
| Stated production date | 29/09/2021 |
| Product type | Coating |
| Sample reception | 01/10/2021 |

2 Brief Evaluation of the Results

| Regulation or protocol | Conclusion | Version of regulation or protocol |
|--------------------------|---|--|
| French VOC Regulation |  | Decree of March 2011 (DEVL1101903D) and Arrêté of April 2011 (DEVL1104875A) modified in February 2012 (DEVL1133129A) |
| French CMR components | Pass | Regulation of April and May 2009 (DEVP0908633A and DEVP0910046A) |
| Italian CAM Edilizia | Pass | Decree 11 October 2017 (GU n.259 del 6-11-2017) |
| ABG/AgBB | Pass | Ausschuss zur gesundheitlichen Bewertung von Bauprodukten (June 2021) |
| Belgian Regulation | Pass | Royal decree of May 2014 (C-2014/24239) |
| Indoor Air Comfort® | Pass | Indoor Air Comfort 7.0 of May 2020 |
| Indoor Air Comfort GOLD® | Pass | Indoor Air Comfort GOLD 7.0 of May 2020 |

Full details based on the testing and direct comparison with limit values are available in the following pages
 Regarding pass/fail decision rule please see appendix


 Rasmus Verdier
 Analytical Service Manager


 Rasmus Stengaard Christensen
 Analytical Service Manager, MSc in Chemistry